



Certificate Number 50679/FS-G
BAFE Number NSI00317/FS-G

National Security Inspectorate Certificate of Approval

Scutum UK Ltd

Scutum House, 28 Mill Road Industrial Estate, Linlithgow, West Lothian, EH49
7SF

Has been assessed by the National Security Inspectorate (NSI) for the

Fire Gold Approval Scheme

and satisfies the requirements of:

Scope

The Design, Installation, Commissioning and Handover, Verification and Maintenance of Fire Detection and Alarm Systems to BS 5839-1, The Design, Installation, Commissioning and Handover and Verification and Maintenance of Fixed Gaseous Fire Suppression Systems

Demonstrating compliance with

BAFE SP203-1 - BAFE Scheme Document, BAFE SP203-3 - BAFE Scheme Document , BS 5839-1:2017 - Fire Detection and Fire Alarm System, BS 6266-1:2011 - Electronic Equipment Installations, BS 7273-1:2006 - Operation of Fire Protection Measures, BS EN 15004-1:2008 - Fixed Firefighting Systems. Gas Extinguishing Systems, BS EN ISO 9001:2015 - Quality Management Systems, NSI FSQS 121 - NSI Quality Schedule - Fire Systems

Original Issue Date 03/10/2012

Effective Date 12/02/2024

Valid Until 11/02/2027

Authorised by Richard Fogelman
NSI Chief Executive





National Security Inspectorate

Supplement to NSI Certificate of Approval No 50679/FS-G

**This supplement is valid when accompanied by the referenced NSI Certificate of Approval
The accompanying NSI Certificate verified that we have approved:**

Scutum UK Ltd

Scutum House, 28 Mill Road Industrial Estate, Linlithgow, West Lothian, EH49
7SF

This supplement verifies that the following locations are included in the approval in addition to the location referenced above:

Oxford

Certificate and Supplement Effective Date: 12/02/2024